

Confirmation

drinking water hygienic suitability in accordance with KTW-BWGL - Annex D (edition: 07.03.2022)

Material: novapress® 880

Range of application: Small area components of equipment items with a surface area in contact with water < 1 % in the equipment item (P3)

Risk group: P3 - based on type testing

Operating temperature: Cold - and Hot Water (23°C and 85°C)

Test report: Hygiene Institut des Ruhrgebietes Gelsenkirchen
test report no. K-381282-23-Ä-Pl/st from 15 Febr. 2024

We hereby confirm compliance with the requirements in accordance with the KTW BWGL - Annex D for small area components of equipment with a surface area in contact with water < 1 % for the cold and hot water range (23°C and 85°C).

In addition to the requirements according to P3, a recipe test has already been passed.

Bad Berneck, 16 May 2024



i.V. Dipl.-Ing. Andreas Will
- Manager R&D Industry -



i.A. Dr. Ing. Andreas Mierzwa
- Application Engineer -