

Confirmation

drinking water hygienic suitability in accordance with KTW-BWGL - Annex D (edition: 07.03.2022)

Material: novapress® 880

Range of application: Components of equipment items with a surface area in contact with water < 10% in the equipment item (P2)

Risk group: P2 – based on type testing

Operating temperature: Cold - and Hot Water (23°C and 85°C)

Test report: Technologiezentrum Wasser - Karlsruhe
Test report no. 5-0507/24 T01 from 02.10.2024

Performance of migration tests:

Migration test in cold water (23 ± 2) °C:

Requirements: fulfilled

Migration test in hot water (85 ± 2) °C:

Requirements: fulfilled

We hereby confirm compliance with the requirements in accordance with the KTW BWGL - Annex D for components of equipment with a surface area in contact with water < 10 % for the cold and hot water range (23°C and 85°C).

The confirmation of conformity is valid up to 02 October 2029.

Bad Berneck, 08.10.2024



i.V. Dipl.-Ing. Andreas Will
- Manager R&D Industry -



i.A. Dr. Ing. Andreas Mierzwa
- Application Engineer -